

# CHPQA PROGRAMME

## Metering Requirements & Data Quality

Pete Edwards

Senior Consultant, CHPQA

# Introduction to Metering Requirements

- Our audits & validations have shown that many RPs are still unclear about CHPQA metering & uncertainty requirements.
- Therefore, a brief review of the requirements is given here.
- The metering uncertainty requirements given here are for schemes > 2MWe.

# Metering Requirements

- All Fuel Inputs, Generated Power Outputs & Useful Heat Outputs associated with CHPQA schemes must be monitored.
- In all cases, monitoring of the energy streams must be accomplished using appropriate **metering**.
- Although, there are some cases where indirect metering/monitoring is acceptable.
- Allowable uncertainties for each case, are given in the appropriate Guidance Note.



# CHPQA Metering Requirements

<ul style="list-style-type: none"> <li>Fuel Inputs, kWh</li> </ul>	±2.0% of reading
<ul style="list-style-type: none"> <li>Energy <u>inputs</u> as steam or hot water, kWh</li> </ul>	As for steam or hot water as appropriate (see below)
<ul style="list-style-type: none"> <li>Heat metering, of hot water, thermal fluid or other liquid heat circulating loops, kWh,</li> </ul>	Metering to BS EN 1434-1:2007, metrological Class 3 (typically 4.5% of reading) with concessions for Schemes with TPC <2MWe), see GN16.15 – 16.16;
<ul style="list-style-type: none"> <li>Heat metering, of steam flows, kWh</li> </ul>	±2.0% of full scale on ±3.0% of reading
<ul style="list-style-type: none"> <li>Electric power, kWh</li> </ul>	Metering to applicable BS and Class dependant on rating, see GN15.7
<ul style="list-style-type: none"> <li>Indirect measurement or calculation of energy input or output, kWh</li> </ul>	±2.0% of value, except for heat outputs from Schemes with TPC <2MWe where ±5.0% of value applies.



# Do all schemes have to meter their heat output ?

- No!
- Simple RE schemes below 2MWe using circulating hot water are **not** required to meter heat outputs, if **no** heat rejection facility is installed .
  - Instead can use H:P ratio and the metered power output to determine heat.
- Indirect Methods, as agreed with CHPQA, still apply for monitoring Direct use of Exhaust Gases (see GN 21.2 & 21.3).

# Heat Metering Options – Hot Water

- Stand alone commercially available heat meters (fully integrated heat meters) to BS EN1434:2007
- Heat metering by computation within control systems, ie BMS:
  - using measured flow and return temperatures, and measured flow rate
- An alternative for Schemes below 2MWe with a dump facility:
  - Use two matched pairs of t/c and the design H:P




# Uncertainties and Uncertainty Adjustment Factors

- Overall Uncertainties for Individual Fuel & Heat Metering Devices, together with Uncertainty Budgets, are calculated using GN17, which offers default values for all 5 elements of meter uncertainty.
- Overall Uncertainties for **Indirect** Measurement of Fuel or Heat Flows are computed using GN 18, as are those that involve **Subtraction** of metered streams.
- Excess Uncertainty (**U<sub>xs</sub>**) and Uncertainty Adjustment Factors for Individual Fuel, Electricity & Heat Metering Devices (FOI, FOP & FOH) are calculated using GN 19.
- Uncertainty adjustments only applied to schemes >2MWe.



# Case Study



# CASE STUDY

The uncertainty of the metering devices shown in Fig 3 are now considered in turn:

## Fuel Metering

- Uncertainty of the Transco Gas meter (M1) is accepted as  $\pm 1.5\%$ , & it meets the  $\pm 2\%$  best practice requirement.
- Excess Uncertainty of M1 = 0; & Uncertainty Adjustment FOI = 1.000.

## Generated Power Metering

- Generated Power meters (M3 & M4) are stamped as Class 1.0. The GT & ST specification documents ratings of 9.0 & 2.5 MWe, respectively.
- Therefore, both meters meet best practice requirements of GN15.7.
- Excess Uncertainty for both = 0; & Overall FOP = 1.000.

## Heat Metering

- Overall Uncertainties of Steam meters (M5 & M6) are computed individually from GN17 as 2.30% & 3.00% respectively.
- best practice requirement is 3.0% for each meter
- Excess Uncertainty and Overall Uncertainty Adjustment Factor for the combination of meters (FOH) is determined from GN 19.
- Excess Uncertainty of = 0; & Uncertainty Adjustment FOH = 1.000



# GN17 Uncertainty Assessment

Example GN17-1 – Calculation of Flow Meter Uncertainty(Work Sheet)

Flow Meter	Tag Number: <b>M9(FQ)</b>	Metered fluid: <b>MP Steam</b>			
Line conditions	Pressure, bar(gauge) <b>10</b>	Temperature, °C <b>200</b>			
Meter type – Primary device (tick appropriate box)	Orifice Plate <input checked="" type="checkbox"/>	Venturi	Averaging pitot	“V-cone”	“Gilflow”
	Vortex shedding	Coriolis	Turbine	Other (please specify)	
Table of Uncertainties	Ref GN	Effective Uncertainty U <sub>e</sub>			U <sub>e</sub> <sup>2</sup>
		Default value of U <sub>e</sub> , %	Claimed value of U <sub>e</sub> , %	Ref to source data attached	
Primary meter uncertainty	17.34	1.0	<b>1.0</b>	default	<b>1.000</b>
Transmitter and computations	17.35	1.0	1.0	default	<b>1.000</b>
Fluctuations in fluid properties	17.36 to 17.44	Table GN17-2: <b>3.0</b> Uncompensated <b>SH Steam</b>			<b>9.0000</b>
Time elapsed since last calibration (transmitter to output value)	17.45	Table GN17-3: <b>0.0</b> <b>18-months</b>	Use default value		<b>0.0000</b>
Time elapsed since last calibration or inspection of primary flow device	17.46	Table GN17-4: <b>3.0</b> <b>6-years</b>	Use default value		<b>9.0000</b>
<b>Sum of all U<sub>e</sub><sup>2</sup> = U<sup>2</sup></b>					<b>Total</b> 20.000
<b>Overall Uncertainty, U =Square root U<sup>2</sup></b>					<b>4.47%</b>
<b>Acceptable Uncertainty for “Best Practice”,UBP (GN17.12-GN17.14)</b>					<b>3.00%</b>
<b>Excess Uncertainty, U<sub>x</sub> = U minus UBP (U<sub>x</sub> = 0 if U &lt;UBP)</b>					<b>1.47%</b>

# Uncertainty Adjustment Factors

Meter or Calc. No.	Description of Output (e.g. MP steam to site)	Annual Heat Output (From Form F4, Section 6c)	Fraction of QHO F	Acceptable Uncertainty for Best Practice $U_{BP}$	Actual Uncertainty U	Excess Uncertainty $U_x = U - U_{BP}$ (if $U < U_{BP}$ , $U_x = 0.00$ )	Individual Adjustment Factor $F_1 = 1 - (U_x / 100)$	Weighed Adjustment Factor $F_W = F \times F_1$
		MWh	(4 decimal places)	% (2 decimal places)			(4 decimal places)	
M9	Steam	10000	0.8333	3.00	4.47	1.47	0.9853	0.8211
M10	HTHW	2000	0.0988	3	2	0.00	1.0000	0.0988
			0.0000			0.00	1.0000	0.0000
			0.0000			0.00	1.0000	0.0000
<b>Total</b>		12000	0.9322	<b>Overall Adjustment Factor FOH</b>			0.9199	0.920

$$\text{Heat efficiency} = (\text{QHO} \times \text{FOH}) / (\text{TFI} \times \text{FOI})$$

# Data Quality

- Meter Reading
- Data Logging
- Record keeping
- Calibration
  - Regular schedule
  - (<2MWe)

CHP MONTHLY LOG

READING DATE	HEAT METER (MMH)	HOURS RUN	GAS INPUT	ELECTRICITY OUTPUT (MWH)	INITIALED
1-Jun-2005	2665.89	10886.04	615820.2	2042657	[initials]
1-Jul-2005	2750.85	11397.16	647728.5	2148475	[initials]
1-Aug-2005	2525.71	11033.56	619778.4	2254352	[initials]
1-Sep-2005	3083.07	12469.07	710348.2	235719.9	[initials]
1-Oct-2005	3253.30	12570.0	740714.1	2456165	[initials]
1-Nov-2005	3314.27	13421.16	768895.6	2520281	[initials]
1-Dec-2005	3464.6	13540.0	800312.0	2659007	[initials]
1-Jan-2006	3612.33	14440.23	830521.7	2743771	[initials]
1-Mar-2006					
1-Apr-2006					
1-May-2006					
1-Jun-2006					
1-Jul-2006					
1-Aug-2006					
1-Sep-2006					
1-Oct-2006					
1-Nov-2006					
1-Dec-2006					
1-Jan-2007					
1-Feb-2007					
1-Mar-2007					
1-Apr-2007					
1-May-2007					
1-Jun-2007					

